

LOCATION 119 Bridgeport LN. CITY GASTON, GA
BETWEEN Beacon Hills DR. STREET & Cul-de-Sac STREET

	SIZE	TYPE	LENGTH	INSTALLED	RETIRED	RENEWED
MAIN TO BLDG.	<u>3/4"</u>	<u>P</u>	<u>70'</u>	<u>4-16-98</u>		
MAIN TO PROP. LINE	<u>3/4"</u>	<u>P</u>	<u>10'</u>			
PROP. LINE TO BLDG.	<u>3/4"</u>	<u>P</u>	<u>68'</u>			


ENTERS: 119 BRANCHED INTO:
TAP SIZE: 1/2 PRESSURE 60 PSI _____ INCHES W C LOCATION 304' SW. of center of Beacon Hills DR.

PRESSURE TEST: @ 100 PSI FOR 1/4 HRS BY S. H. H. H. H.
MAIN-SIZE 2" C.I. _____ BARE STEEL _____ COATED STEEL _____ PLASTIC ☒ YEAR INSTALLED _____

DEPTH: 3 FT. 0 IN LOCATION 25' NW. of center of Bridgeport LN.

"A" P/S READING P TOTAL ANODES 1# 0 17# 0 L.R. # 261063

REMARKS:



Test Station		
Reading & Location	Lead	Volts
P/S Pipeline Lead - Red New Service	<u>S</u>	
P/S Pipeline Lead - White Existing Main	<u>E</u>	

ENG. DEPT. USE ONLY