

LOCATION 503 Bridgestone CT CITY GASTONIA

BETWEEN Patrick Rd STREET & Cut-de-Sac STREET

	SIZE	TYPE	LENGTH	INSTALLED	RETIRED	RENEWED
MAIN TO BLDG.	<u>3/4"</u>	<u>P</u>	<u>90'</u>	<u>12-15-97</u>		
MAIN TO PROP. LINE	<u>3/4"</u>	<u>P</u>	<u>10'</u>			
PROP. LINE TO BLDG.	<u>3/4"</u>	<u>P</u>	<u>80'</u>			

ENTERS: 503 BRANCHED INTO:

TAP SIZE: 3/4" PRESSURE 60 PSI \_\_\_\_\_ INCHES W.C. LOCATION 100' W. of center of

Patrick Rd


PRESSURE TEST. @ 100 PSI FOR 1/4 HRS. BY S. Huff

MAIN-SIZE 2" C.I. \_\_\_\_\_ BARE STEEL \_\_\_\_\_ COATED STEEL \_\_\_\_\_ PLASTIC ☒ YEAR INSTALLED 1996

DEPTH: 3 FT 0 IN LOCATION 19' S. of center of Bridgestone CT

"A" P/S READING \_\_\_\_\_ P TOTAL ANODES 1# 0 17# 0 L.R. # 845880

REMARKS:



Test Station		
Reading & Location	Lead	Volts
P/S Pipeline Lead - Red New Service	<u>S</u>	
P/S Pipeline Lead - White Existing Main	<u>E</u>	

ENG. DEPT. USE ONLY