

LOCATION 516 Bridgestone Cr. CITY CASSTONIA
BETWEEN Patrick Rd. STREET & Cut-de-Sac STREET


| | SIZE | TYPE | LENGTH | INSTALLED | RETIRED | RENEWED |
|---------------------|------|------|--------|-----------|---------|---------|
| MAIN TO BLDG. | 3/4" | P | 97' | 9-27-97 | | |
| MAIN TO PROP. LINE | 3/4" | P | 10' | | | |
| PROP. LINE TO BLDG. | 3/4" | P | 87' | | | |

ENTERS 516 BRANCHED INTO:
TAP SIZE: 3/4" PRESSURE 60 PSI INCHES W.C. LOCATION 398' S. of center of Patrick Rd.

PRESSURE TEST: @ 100 PSI FOR 1/4 HRS BY S. Hurtado
MAIN-SIZE 2" C.I. BARE STEEL COATED STEEL PLASTIC ✓ YEAR INSTALLED 1996
DEPTH: 3 FT 0 IN. LOCATION 20' E of center of Bridgestone Cr

"A" P/S READING P TOTAL ANODES 1# 0 17# 0 L.R. # 634073

REMARKS:



| Test Station | | |
|---|----------|-------|
| Reading & Location | Lead | Volts |
| P/S Pipeline Lead - Red New Service | S | |
| P/S Pipeline Lead - White Existing Main | E | |

ENG. DEPT. USE ONLY