

LOCATION 1201 BRIDGEWOOD LN.

CITY GASTONIA

BETWEEN FAREWELL DR.

STREET &

STREET

	SIZE	TYPE	LENGTH	INSTALLED	RETIRED	RENEWED
MAIN TO BLDG.	3/4"	PL.	67'	11-17-98		
MAIN TO PROP LINE	3/4"	PL	5'	11-17-98		
PROP. LINE TO BLDG.	3/4"	PL.	62'	11-17-98		

ENTERS: SAME

BRANCHED INTO:

TAP SIZE 3/4" PRESSURE 60 PSI _____ INCHES W C LOCATION 37' EAST OF CEN. OF FAREWELL DR.


PRESSURE TEST @ 100 PSI FOR 1/4 HRS BY R. Rulley

MAIN-SIZE 2" C.I. _____ BARE STEEL _____ COATED STEEL _____ PLASTIC ☒ YEAR INSTALLED 1994

DEPTH. 4 FT IN LOCATION 25' SOUTH OF CEN. OF BRIDGEWOOD LN.

"A" P/S READING PL. TOTAL ANODES 1# _____ 17# _____ L.R. # _____

REMARKS



Test Station		
Reading & Location	Lead	Volts
P/S Pipeline Lead - Red New Service	S	
P/S Pipeline Lead - White Existing Main	E	

ENG. DEPT. USE ONLY