

LOCATION 538 & 548 Bridle Path Tr.CITY GASTONIABETWEEN Derby CtSTREET & Whitson


STREET

	SIZE	TYPE	LENGTH	INSTALLED <i>tie over</i>	RETIRED	RENEWED
MAIN TO BLDG.	<sup>548</sup> 3/4"	Plastic	133'	4/23/94		
MAIN TO PROP. LINE	<sup>538</sup> 3/4"	Plastic	40'			
PROP. LINE TO BLDG.						

ENTERS: 538 & 548

BRANCHED INTO:

TAP SIZE: <u>1/2"</u>	PRESSURE <u>60</u> P.S.I.	INCHES W.C.	LOCATION <u>East side of 538</u> <u>North side of 548</u>
-----------------------	---------------------------	-------------	--

PRESSURE TEST: @ 100 psi For 1/4 Hrs. By DTMAIN-SIZE 2" C.I.      BARE STEEL      COATED STEEL      PLASTIC ✓ YEAR INSTALLED 1992DEPTH: 3' Ft. 0 In. LOCATION"A" P/S READING 0 TOTAL ANODES 1\*0 17\*0 L.R. #     REMARKS: Tied over 131' of 3/4" Plastic service to 548.tied over 40' of 3/4" Plastic service to 538Split service

Test Station		
Reading & Location	Lead	Volts
P/S Pipeline Lead - Red New Service	S	
P/S Pipeline Lead - White Existing Main	E	

ENG. DEPT. USE ONLY