

LOCATION 642 Bridle Path Tr. CITY GASTONIA
BETWEEN Gardner Park Dr. STREET & Derby Ct STREET


	SIZE	TYPE	LENGTH	INSTALLED	RETIRED	RENEWED
MAIN TO BLDG.	3/4"	Plastic	126'			4/30/94
MAIN TO PROP. LINE	3/4"		44'			
PROP. LINE TO BLDG.	3/4"		82'			

ENTERS: 642 BRANCHED INTO:
TAP SIZE: 1/2" PRESSURE 60 P.S.I. _____ INCHES W.C. LOCATION East side of 642

PRESSURE TEST: @ 100 psi For 1/4 Hrs. By DT
MAIN-SIZE 4" C.I. _____ BARE STEEL _____ COATED STEEL _____ PLASTIC ☒ YEAR INSTALLED 1992
DEPTH: 3 Ft. 0 In. LOCATION South side of Gardner Park Dr.

"A" P/S READING 0 TOTAL ANODES 1# 0 17# 0 L.R. # _____

REMARKS:



Test Station		
Reading & Location	Lead	Volts
P/S Pipeline Lead - Red New Service	S	
P/S Pipeline Lead - White Existing Main	E	

ENG. DEPT. USE ONLY