

LOCATION 1734 Bridlewood CtCITY GastoniaBETWEEN Dead EndSTREET & Windy Rush

STREET

	SIZE	TYPE	LENGTH	INSTALLED	RETIRED	RENEWED
MAIN TO BLDG.	<u>3/4</u>	<u>C/W</u>	<u>5</u>	<u>Relocated</u>	<u>7-9-96</u>	
MAIN TO PROP. LINE						
PROP. LINE TO BLDG.						

ENTERS: 1734 Bridlewood Ct.BRANCHED INTO: - 0 -TAP SIZE: 3/4PRESSURE 60 PSI

INCHES W.C.

LOCATION

PRESSURE TEST: @ 105 PSIFOR 1/4 HRS.BY Scott CaldwellMAIN SIZE 3/4

C.I. _____

BARE STEEL _____

COATED STEEL ☒

PLASTIC _____


YEAR INSTALLED _____

DEPTH: 1 FT. 6 IN.

LOCATION

"A" P/S READING .5TOTAL ANODES 1# 1 17# 0

L.R. # _____

REMARKS: Relocated Riser

Test Station		
Reading & Location	Lead	Volts
P/S Pipeline Lead - Red New Service	<u>S Riser</u>	<u>1.1</u>
P/S Pipeline Lead - White Existing Main	<u>E</u>	

ENG. DEPT. USE ONLY