

LOCATION 1742 Bridlewood Ct CITY GASTANIA

BETWEEN Windy Rush STREET & STREET

	SIZE	TYPE	LENGTH	INSTALLED	RETIRED	RENEWED
MAIN TO BLDG.	<u>3/4'</u>	<u>Plastic</u>	<u>84'</u>	<u>1/20/96</u>		
MAIN TO PROP. LINE	<u>3/4"</u>		<u>12'</u>			
PROP. LINE TO BLDG.	<u>3/4"</u>		<u>72'</u>			

ENTERS: 1742 BRANCHED INTO:

TAP SIZE: 3/8" PRESSURE 60 PSI _____ INCHES W.C. LOCATION East side of 1742

PRESSURE TEST: @ 100 PSI FOR 1/4 HRS BY RT

MAIN SIZE 3/4" C.I. _____ BARE STEEL _____ COATED STEEL ☒ PLASTIC _____ YEAR INSTALLED 1977

DEPTH: 1 FT. 6 IN LOCATION South side of 1734

"A" P/S READING 1.20 TOTAL ANODES 1# 0 17# 0 L.R. # 010694

REMARKS.

Test Station			ENG. DEPT. USE ONLY
Reading & Location	Lead	Volts	
P/S Pipeline Lead - Red New Service	<u>S</u>		
P/S Pipeline Lead - White Existing Main	<u>E</u>		

