

LOCATION 121 Bright Ave CITY GASTONIA
BETWEEN Bright Ave STREET & Gamble STREET


	SIZE	TYPE	LENGTH	INSTALLED	RETIRED	RENEWED
MAIN TO BLDG.	3/4"	PLASTIC	68'	11/31/97		
MAIN TO PROP LINE	3/4"		10			
PROP. LINE TO BLDG.	3/4'		58'			

ENTERS: 121 BRANCHED INTO:
TAP SIZE. 1/2" PRESSURE 60 PSI _____ INCHES W.C. LOCATION North side of 121

PRESSURE TEST: @ 100 PSI FOR 1/4 HRS BY DT
MAIN-SIZE 2" C I _____ BARE STEEL _____ COATED STEEL _____ PLASTIC ✓ YEAR INSTALLED 1993
DEPTH: 2 FT 6 IN LOCATION East side of Bright Ave

"A" P/S READING 0 TOTAL ANODES 1# 0 17# 0 L.R. # 049635

REMARKS

	Test Station			ENG. DEPT. USE ONLY
	Reading & Location	Lead	Volts	
	P/S Pipeline Lead - Red New Service	S		
	P/S Pipeline Lead - White Existing Main	E		