

| | | | |
|--------------------------------|--|-----------------------------|--|
| LOCATION <u>126 Bright Ave</u> | | CITY <u>GASTANIA</u> | |
| BETWEEN <u>Gamble Ave</u> | | STREET <u>8 Edgewood Rd</u> | |

| | SIZE | TYPE | LENGTH | INSTALLED | RETIRED | RENEWED |
|---------------------|------|---------|--------|-----------|---------|---------|
| MAIN TO BLDG. | 3/4" | Plastic | 121' | 10/21/94 | | |
| MAIN TO PROP. LINE | 3/4" | | 41 | | | |
| PROP. LINE TO BLDG. | 3/4" | | 80' | | | |

ENTERS: 126 -BRANCHED INTO:

TAP SIZE: 1/2" PRESSURE _____ P.S.I. _____ INCHES W.C. LOCATION North side of 126

PRESSURE TEST: @ 100 psi For 4 Hrs. By DT

MAIN-SIZE 2" C.I. _____ BARE STEEL _____ COATED STEEL _____ PLASTIC ☒ YEAR INSTALLED 1993

DEPTH: 2' Ft. 6" In. ⊗ LOCATION West side of Bright Ave

"A" P/S READING 0 TOTAL ANODES 1# 0 17# 0 L.R. # 580737

REMARKS:

| Test Station | | |
|--|------|-------|
| Reading & Location | Lead | Volts |
| P/S Pipeline Lead - Red New Service | S | |
| P/S Pipeline Lead - White Existing Main | E | |

ENG. DEPT. USE ONLY