

LOCATION 402 W. Bond CITY Castroville
BETWEEN Ratcliff Rd. STREET & Walnut STREET

	SIZE	TYPE	LENGTH	INSTALLED	RETIRED	RENEWED
MAIN TO BLDG.	<u>3/4</u>	<u>bare</u>	<u>14'</u>		<u>10-19-95</u>	
MAIN TO PROP. LINE						
PROP. LINE TO BLDG.						

ENTERS: 402 BRANCHED INTO: 0

TAP SIZE: 3/4 IN. PRESSURE 20 P.S.I. _____ INCHES W.C. LOCATION _____

PRESSURE TEST: @ _____ psi For _____ Hrs. By _____


MAIN SIZE 3/4 C.I. _____ BARE STEEL _____ COATED STEEL ☒ PLASTIC _____ YEAR INSTALLED _____

DEPTH: 2 Ft. 0 In. LOCATION _____

"A" P/S READING 115 TOTAL ANODES 1* 1 17* _____ L.R. # _____

REMARKS: _____

Leak Ext 3/4 CW Stub behind Carb.



Test Station		
Reading & Location	Lead	Volts
P/S Pipeline Lead - Red New Service	<u>S</u>	<u>Retired</u>
P/S Pipeline Lead - White Existing Main	<u>E</u>	

ENG. DEPT. USE ONLY