

LOCATION 402 N. Bond ST. CITY Easton
BETWEEN Ratched STREET & Walnut STREET

	SIZE	TYPE	LENGTH	INSTALLED	RETIRED	RENEWED
MAIN TO BLDG.	<u>3/4</u>	<u>P</u>	<u>14'</u>			
MAIN TO PROP. LINE	<u>3/4</u>	<u>P</u>	<u>5'</u>			<u>11-8 SS</u>
PROP. LINE TO BLDG.	<u>3/4</u>	<u>P</u>	<u>9'</u>			

ENTERS: 402 BRANCHED INTO: AB

TAP SIZE: 3/4 PRESSURE 20 P.S.I. _____ INCHES W.C. LOCATION _____


PRESSURE TEST: @ 100 psi For 4 Hrs. By EP

MAIN-SIZE 3/4 C.I. _____ BARE STEEL _____ COATED STEEL ☒ PLASTIC _____ YEAR INSTALLED _____

DEPTH: 2 Ft. 0 In. LOCATION _____

"A" P/S READING 1.4 TOTAL ANODES 1# 017 # 0 L.R. # _____

REMARKS: _____



Test Station		
Reading & Location	Lead	Volts
P/S Pipeline Lead - Red New Service	<u>S</u>	<u>1.45</u>
P/S Pipeline Lead - White Existing Main	<u>E</u>	

ENG. DEPT. USE ONLY