

LOCATION 406 & 408 N. BROAD CITY GAST  
BETWEEN RATCHFORD STREET & WALNUT STREET

	SIZE	TYPE	408 LENGTH	406 LENGTH	INSTALLED	RETIRED	RENEWED
MAIN TO BLDG.	3 1/4"	D	67'	17'		10-22-	96
MAIN TO PROP. LINE	"	"	5'	0'			
PROP. LINE TO BLDG.	"	"	62'	17'			

ENTERS: 408 BRANCHED INTO: 406  
TAP SIZE: 3 1/4" PRESSURE 60 P.S.I. \_\_\_\_\_ INCHES W.C. LOCATION S. of 408  
N. of 406


PRESSURE TEST: @ 100 psi For 1 1/4 Hrs. By GR

MAIN-SIZE 2 C.I. \_\_\_\_\_ BARE STEEL \_\_\_\_\_ COATED STEEL \_\_\_\_\_ PLASTIC ☒ YEAR INSTALLED 96

DEPTH: 3 Ft. \_\_\_\_\_ In. LOCATION E. of N. BROAD

"A" P/S READING P TOTAL ANODES 1# \_\_\_\_\_ 17# \_\_\_\_\_ L.R. # \_\_\_\_\_

REMARKS:  
\_\_\_\_\_  
\_\_\_\_\_  
\_\_\_\_\_



Test Station		
Reading & Location	Lead	Volts
P/S Pipeline Lead - Red New Service	S	7
P/S Pipeline Lead - White Existing Main	E	

ENG. DEPT. USE ONLY