

LOCATION 410 N. Broad CITY Gastonia  
BETWEEN walnut STREET & Ratchford STREET

|                     | SIZE       | TYPE     | LENGTH    | INSTALLED       | RETIRED                  | RENEWED             |
|---------------------|------------|----------|-----------|-----------------|--------------------------|---------------------|
| MAIN TO BLDG.       | <u>3/4</u> | <u>P</u> | <u>2'</u> | <u>12-14-96</u> | <u>tied over 60'</u>     | <u>3/4 P. serv.</u> |
| MAIN TO PROP. LINE  |            |          |           |                 | <u>to new 2" p. main</u> |                     |
| PROP. LINE TO BLDG. |            |          |           |                 |                          |                     |

ENTERS: 410 BRANCHED INTO: —

TAP SIZE: 1/2 PRESSURE \_\_\_\_\_ PSI \_\_\_\_\_ INCHES W.C. LOCATION 19' E. of cap  
M. Broad st

PRESSURE TEST: @ 100 PSI FOR 1/4 HRS. BY JP

MAIN-SIZE 2" C.I. \_\_\_\_\_ BARE STEEL \_\_\_\_\_ COATED STEEL \_\_\_\_\_ PLASTIC ☒ YEAR INSTALLED 1996

DEPTH: 3 FT. 0 IN. LOCATION \_\_\_\_\_

"A" P/S READING P TOTAL ANODES 1# \_\_\_\_\_ 17# \_\_\_\_\_ L.R. # \_\_\_\_\_

REMARKS: \_\_\_\_\_

\_\_\_\_\_

\_\_\_\_\_

\_\_\_\_\_

\_\_\_\_\_

\_\_\_\_\_

\_\_\_\_\_

\_\_\_\_\_


\_\_\_\_\_

\_\_\_\_\_

\_\_\_\_\_

\_\_\_\_\_

\_\_\_\_\_



| Test Station                               |          |          |
|--|----------|----------|
| Reading & Location                         | Lead     | Volts    |
| P/S Pipeline Lead - Red<br>New Service     | <u>R</u> | <u>P</u> |
| P/S Pipeline Lead - White<br>Existing Main | <u>E</u> |          |

ENG. DEPT. USE ONLY