

LOCATION 507 & 509 N. BROAD ST CITY East
BETWEEN Reverse Curve STREET & Walnut STREET

	SIZE	TYPE	509 LENGTH	507	INSTALLED	RETIRED	RENEWED
MAIN TO BLDG.	<u>3/4"</u>	<u>P</u>	<u>78</u>	<u>53</u>		<u>10 - 16</u>	<u>- 96</u>
MAIN TO PROP. LINE	<u>"</u>	<u>"</u>	<u>35</u>	<u>0</u>			
PROP. LINE TO BLDG.	<u>"</u>	<u>"</u>	<u>43</u>	<u>53</u>			

ENTERS: 509 BRANCHED INTO: 507
TAP SIZE: 3/4" PRESSURE 60 P.S.I. _____ INCHES W.C. LOCATION S. of 509
W. " 507


PRESSURE TEST: @ 100 psi For 1 1/4 Hrs. By GL

MAIN-SIZE 2 C.I. _____ BARE STEEL _____ COATED STEEL _____ PLASTIC / YEAR INSTALLED 96

DEPTH: 3 Ft. In. LOCATION E. side of N. Broad

"A" P/S READING P TOTAL ANODES 1* _____ 17* _____ L.R. # _____

REMARKS:



Test Station		
Reading & Location	Lead	Volts
P/S Pipeline Lead - Red New Service	<u>S</u>	<u>P</u>
P/S Pipeline Lead - White Existing Main	<u>E</u>	

ENG. DEPT. USE ONLY