

LOCATION 518 A-B-C N Broad St CITY GASTONIA

BETWEEN E WALNUT STREET & STREET

	SIZE	TYPE	LENGTH		RETIRED	RENEWED
MAIN TO BLDG.	<u>3/4"</u>	<u>PLASTIC</u>	<u>172'</u>	<u>tie over</u> <u>12/7/96</u>		
MAIN TO PROP. LINE			<u>8'</u>			
PROP. LINE TO BLDG			<u>164'</u>			

ENTERS: 518 A-B-C BRANCHED INTO:

TAP SIZE: 1/2" PRESSURE 60 PSI INCHES W C LOCATION North side of A-B-C


PRESSURE TEST: @ 100 PSI FOR 1/4 HRS BY DT

MAIN-SIZE 2" C.I.        BARE STEEL        COATED STEEL        PLASTIC ✓ YEAR INSTALLED 1996

DEPTH: 3 FT 0 IN LOCATION East side of N Broad St

"A" P/S READING 0 TOTAL ANODES 1# 0 17# 0 I.R. #       

REMARKS: APPS A+B split with APP C. Tied over 140' of Ex 3/4" Plastic sor  
to APPS A+B to new main. tied over 32' of Ex 3/4" Plastic sor APP C  
to new main



Test Station		
Reading & Location	Lead	Volts
P/S Pipeline Lead - Red New Service	<b>S</b>	
P/S Pipeline Lead - White Existing Main	<b>E</b>	

ENG. DEPT. USE ONLY