

LOCATION 522 N Broad St CITY GASTONIA

BETWEEN E WALNUT STREET & STREET

	SIZE	TYPE	LENGTH		RETIRED	RENEWED
MAIN TO BLDG	<u>3/4'</u>	<u>Plastic</u>	<u>62'</u>	<u>tie over</u> <u>12/2/96</u>		
MAIN TO PROP. LINE			<u>10'</u>			
PROP. LINE TO BLDG.			<u>52'</u>			

ENTERS: 522 BRANCHED INTO:

TAP SIZE: 1/2" PRESSURE 60 PSI INCHES W C LOCATION South side of 522


PRESSURE TEST: @ 100 PSI FOR 1/4 HRS. BY DT

MAIN-SIZE 2" C.I.        BARE STEEL        COATED STEEL        PLASTIC ✓ YEAR INSTALLED 1996

DEPTH: 3 FT. 0 IN LOCATION East side of N Broad St

"A" P/S READING 0 TOTAL ANODES 1# 0 17# 0 L.R. #       

REMARKS:



Test Station		
Reading & Location	Lead	Volts
P/S Pipeline Lead - Red New Service	<b>S</b>	
P/S Pipeline Lead - White Existing Main	<b>E</b>	

ENG. DEPT. USE ONLY