


GAS SERVICE RECORD

LOCATION 525 - N. Broad St. CITY Gastonia
 BETWEEN E. Davidson STREET & _____ STREET
 SIZE LENGTH INSTALLED ENLARGED RENEWED
 MAIN TO BLDG. 3/4 86' 11-18-70 AP
 MAIN TO CURB
 CURB TO BLDG.
 ENTERS 3 25 BRANCHED INTO: _____
 TAP SIZE 3/8 LOCATION: North 8 1/2 W. 1/2
 MAIN-SIZE: 1 1/4" DEPTH: 2 FT. 6 INCHES
 LOCATION: East 8 Broad St. PRESS: HIGH
 DRIP POT - LOCATION
 SERVICE FALLS TO: DRIP MAIN HOUSE
 VALVE - LOCATION:
 (OVER FOR SKETCH)

LOCATION 525 B. N. Broad St. CITY Gastonia
 BETWEEN REVERSE CURVE STREET & E. Walnut STREET
 SIZE TYPE LENGTH INSTALLED RETIRED RENEWED
 MAIN TO BLDG. 2" Plastic 264 8-21-92
 MAIN TO PROP LINE 2" " 37
 PROP LINE TO BLDG. 2" " 227
 ENTERS 525 B BRANCHED INTO: _____
 TAP SIZE 1 1/2 PRESSURE 20 P S I INCHES W C LOCATION E. Side Broad St
 PRESSURE TEST: @ 100 psi For 1 Hrs By Benner
 MAIN-SIZE 1 1/2" C I _____ BARE STEEL X COATED STEEL _____ PLASTIC _____ YEAR INSTALLED 1955
 DEPTH: 2 Ft _____ In LOCATION
 "A" P/S READING 5 TOTAL ANODES 1# _____ 17# 2 LR # 214648
 REMARKS:



Test Station		
Reading & Location	Lead	Volts
P/S Pipeline Lead - Red New Service	S	106 Steel Riser
P/S Pipeline Lead - White Existing Main	E	