

LOCATION 525A+525B N Broad St CITY GASTONIA

BETWEEN Reverse Curve STREET & Walnut Ave STREET

	SIZE	TYPE	LENGTH	INSTALLED	RETIRED	RENEWED
MAIN TO BLDG.	(B) 3/4	P	7' Tied over	12-4-96		
MAIN TO PROP. LINE	(A) 2"	P	264 Tied over			
PROP. LINE TO BLDG.						

ENTERS: 525 B BRANCHED INTO: 525

TAP SIZE: 2" PRESSURE 60 PSI \_\_\_\_\_ INCHES W.C. LOCATION 15' E OF N Broad


PRESSURE TEST: @ 100 PSI FOR 1/4 HRS. BY M Park

MAIN-SIZE 2" C.I. \_\_\_\_\_ BARE STEEL \_\_\_\_\_ COATED STEEL \_\_\_\_\_ PLASTIC X YEAR INSTALLED 96

DEPTH: 3 FT. 0 IN. LOCATION 470' N OF Walnut

"A" P/S READING 1.4 Riser TOTAL ANODES 1# \_\_\_\_\_ 17# \_\_\_\_\_ L.R. # \_\_\_\_\_

REMARKS:

	Test Station			ENG. DEPT. USE ONLY
	Reading & Location	Lead	Volts	
	P/S Pipeline Lead - Red New Service	S	1.4 Riser	
	P/S Pipeline Lead - White Existing Main	E		