

LOCATION 800A N Broad St CITY GASTONIA

BETWEEN PAVED Drive STREET & Reverse Curve STREET

	SIZE	TYPE	LENGTH	INSTALLED	RETIRED	RENEWED
MAIN TO BLDG.	<u>2"</u>	<u>P</u>	<u>11'</u>	<u>11/27/97</u>		
MAIN TO PROP LINE	<u>2"</u>		<u>11</u>			
PROP LINE TO BLDG.	<u>2"</u>		<u>11</u>			

ENTERS: 800A BRANCHED INTO

TAP SIZE 2" PRESSURE 60 PSI \_\_\_\_\_ INCHES W/C LOCATION West side of Compressor


PRESSURE TEST @ 100 PSI FOR 3 HRS BY DT

MAIN-SIZE 2" C.I. \_\_\_\_\_ BARE STEEL \_\_\_\_\_ COATED STEEL \_\_\_\_\_ PLASTIC ☒ YEAR INSTALLED 1997

DEPTH 3 FT 0 IN LOCATION West side of Compressor

"A" P/S READING 0 TOTAL ANODES 1# 0 17# 0 L.R. # 10178

REMARKS:



Test Station		
Reading & Location	Lead	Volts
P/S Pipeline Lead - Red New Service	<b>S</b>	
P/S Pipeline Lead - White Existing Main	<b>E</b>	

ENG. DEPT. USE ONLY