

LOCATION 107 S Broad ST CITY GASTONIA
 BETWEEN MAIN STREET & FRANKLIN AVE STREET

	SIZE	TYPE	LENGTH	INSTALLED	RETIRED	RENEWED
MAIN TO BLDG	3/4"	Plastic	36'	4/9/99		
MAIN TO PROP LINE	3/4"		5'			
PROP LINE TO BLDG	3/4"		31'			

ENTERS 107 BRANCHED INTO
 TAP SIZE 3/8" PRESSURE 60 PSI _____ INCHES WC LOCATION S Side of 107


PRESSURE TEST @ 100 PSI FOR 4 HRS BY 175

MAIN SIZE 4" C I _____ BARE STEEL _____ COATED STEEL _____ PLASTIC _____ YEAR INSTALLED 1997

DEPTH. _____ FT _____ IN LOCATION West side of S Broad ST

A P/S READING _____ TOTAL ANODES 1# 0 17# _____ LR # 222524

REMARKS



Test Station		
Reading & Location	Lead	Volts
P/S Pipeline Lead Red New Service	S	
P/S Pipeline Lead White Existing Main	E	