

LOCATION 310 S Broad ST CITY Houston  
BETWEEN 2<sup>nd</sup> Ave STREET & STREET


	SIZE	TYPE	LENGTH	INSTALLED	RETIRED	RENEWED
MAIN TO BLDG.	<u>3/4"</u>	<u>Plastic</u>	<u>15'</u>	<u>Tie over</u> <u>4/17/93</u>		
MAIN TO PROP. LINE						
PROP. LINE TO BLDG.						

ENTERS: 310 BRANCHED INTO:  
TAP SIZE: 1/2" PRESSURE 60 P.S.I. INCHES W.C. LOCATION North side of 310

PRESSURE TEST: @ 100 psi For 14 Hrs. By DT  
<sup>ser</sup> MAIN - SIZE 3/4" C.I.      BARE STEEL      COATED STEEL      PLASTIC      YEAR INSTALLED 1993  
DEPTH: 1 Ft. 6 In. LOCATION South side of 306

"A" P/S READING 0 TOTAL ANODES 1\* 0 17\* 0 L.R. #     

REMARKS: Tied over 12' of Ex 3/4" Plastic service to new  
main with 3' of Plastic & ter



Test Station		
Reading & Location	Lead	Volts
P/S Pipeline Lead - Red New Service	S	
P/S Pipeline Lead - White Existing Main	E	

ENG. DEPT. USE ONLY