

LOCATION 316 5-Broad St. CITY Gastonia
BETWEEN 2nd Ave STREET & Brd Ave. STREET


	SIZE	TYPE	LENGTH	INSTALLED	RETIRED	RENEWED
MAIN TO BLDG.	<u>3/4</u>	<u>P</u>	<u>3'</u>	<u>4-17-93</u>	<u>Tred Over 90' Existing</u>	
MAIN TO PROP. LINE					<u>3/4 G/W to new</u>	
PROP. LINE TO BLDG.					<u>2" Plastic W/Air</u>	

ENTERS: 316 5-Broad St. BRANCHED INTO: 0
TAP SIZE: 1/2 PRESSURE: 60 P.S.I. _____ INCHES W.C. LOCATION 176' N of C of 3rd St.

PRESSURE TEST: @ 100 psi For 1/4 Hrs. By RL
MAIN-SIZE 2" C.I. _____ BARE STEEL _____ COATED STEEL _____ PLASTIC ☒ YEAR INSTALLED 1993
DEPTH: 3 Ft. 0 In. LOCATION 16' E of C of Broad St.

"A" P/S READING: 1.15M @ 100 PSI TOTAL ANODES 1# _____ 17# _____ L.R. # _____

REMARKS:



Test Station		
Reading & Location	Lead	Volts
P/S Pipeline Lead - Red New Service	S	Riser .9
P/S Pipeline Lead - White Existing Main	E	

ENG. DEPT. USE ONLY