

LOCATION 1024 Broad St. CITY GAST.
BETWEEN Wood Hill Dr. STREET & Briarwood Ln STREET

	SIZE	TYPE	LENGTH	INSTALLED	RETIRED	RENEWED
MAIN TO BLDG.	<u>3/4"</u>	<u>P.</u>	<u>42' Tieover</u>			<u>9-12-97</u>
MAIN TO PROP. LINE	<u>"</u>	<u>"</u>				
PROP LINE TO BLDG.	<u>"</u>	<u>"</u>				

ENTERS: SAME

BRANCHED INTO:

TAP SIZE: 3/4" PRESSURE 60 PSI _____ INCHES W.C. LOCATION 344' From @ of

Wood Hill Dr.


PRESSURE TEST: @ 100 PSI FOR 1/4 HRS. BY D.F.

MAIN-SIZE 2" C.I. _____ BARE STEEL _____ COATED STEEL _____ PLASTIC ✓ YEAR INSTALLED 1987

DEPTH: 3 FT. 0 IN LOCATION W. of Broad St.

"A" P/S READING P. TOTAL ANODES 1# _____ 17# _____ L.R. # _____

REMARKS:



Test Station		
Reading & Location	Lead	Volts
P/S Pipeline Lead - Red New Service	<u>S</u>	
P/S Pipeline Lead - White Existing Main	<u>E</u>	

ENG. DEPT. USE ONLY