

LOCATION 1315 Broad St. CITY BASTONIA  
BETWEEN Briarwood STREET & Dead End STREET

	SIZE	TYPE	LENGTH	INSTALLED	RETIRED	RENEWED
MAIN TO BLDG.	<u>3/4</u>	<u>Plastic</u>	<u>125'</u>	<u>8-12-97</u>		
MAIN TO PROP. LINE	<u>3/4</u>	<u>Plastic</u>	<u>5'</u>			
PROP. LINE TO BLDG.	<u>3/4</u>	<u>Plastic</u>	<u>120'</u>			

ENTERS: 1315 BRANCHED INTO: 0  
TAP SIZE: 3/8 PRESSURE 60 PSI \_\_\_\_\_ INCHES W.C. LOCATION 259' N of C of Briarwood  
CANE


PRESSURE TEST: @ 100 PSI FOR 1/4 HRS BY RL

MAIN-SIZE 2" C.I. \_\_\_\_\_ BARE STEEL \_\_\_\_\_ COATED STEEL ✓ PLASTIC \_\_\_\_\_ YEAR INSTALLED 1969

DEPTH: 3 FT 0 IN. LOCATION 20' W of C of Broad St.

"A" P/S READING .80 TOTAL ANODES 1# 0 17# 1 L.R. # 527594

REMARKS:



Test Station		
Reading & Location	Lead	Volts
P/S Pipeline Lead - Red New Service	<u>S</u>	<u>Riser</u>
P/S Pipeline Lead - White Existing Main	<u>E</u>	<u>Plastic</u>

ENG. DEPT. USE ONLY