

LOCATION 1616 Brookhaven DR CITY CATON
BETWEEN River Ridge DR STREET & STREET

	SIZE	TYPE	LENGTH	INSTALLED	RETIRED	RENEWED
MAIN TO BLDG	<u>5/8"</u>	<u>P</u>	<u>44'</u>	<u>8-27-03</u>		
MAIN TO PROP LINE	<u>5/8"</u>	<u>P</u>	<u>10'</u>			
PROP LINE TO BLDG	<u>5/8"</u>	<u>P</u>	<u>34"</u>			

ENTERS 1616 BRANCHED INTO
TAP SIZE 3/4" PRESSURE 60 PSI INCHES W.C. LOCATION 204' S. of center of River Ridge DR


PRESSURE TEST @ 100 PSI FOR 44 HRS BY S.G.

MAIN-SIZE 2" C I BARE STEEL COATED STEEL PLASTIC ✓ YEAR INSTALLED 2001

DEPTH 3 FT 0 IN LOCATION E. of center of Brookhaven

"A" P/S READING 7 TOTAL ANODES 1# 0 17# 0 LR #

REMARKS

	Test Station		
	Reading & Location	Lead	Volts
	P/S Pipeline Lead - Red New Service	<u>S</u>	
	P/S Pipeline Lead - White Existing Main	<u>E</u>	