

LOCATION 1632 Brook Haven Dr. CITY Gastonia

BETWEEN Kendall ct. STREET & River Ridge Rd. STREET

	SIZE	TYPE	LENGTH	INSTALLED	RETIRED	RENEWED
MAIN TO BLDG	5/8"	P	79'	10-29-01		
MAIN TO PROP LINE	5/8"	P	8'	"		
PROP LINE TO BLDG	5/8"	P	71'	"		

ENTERS 1632 BRANCHED INTO e

TAP SIZE 1/2" PRESSURE 60 PSI INCHES W/C 72' East LOCATION center of Kendall ct.


PRESSURE TEST @ 100 PSI FOR 1/4 HRS BY J. Woody

MAIN-SIZE 2" C I BARE STEEL COATED STEEL PLASTIC ✓ YEAR INSTALLED 2001

DEPTH 3' FT 0" IN LOCATION 39' north of center of cul-de-sac of Brook Haven Dr.

"A" P/S READING N/A TOTAL ANODES 1# 0 17# 0 LR # C-0109173

REMARKS new 5/8" plastic service
(In rock - pipe pulled into)



Test Station		
Reading & Location	Lead	Volts
P/S Pipeline Lead Red New Service	S	plastic
P/S Pipeline Lead - White Existing Main	E	pipe