

LOCATION 923 BrownCITY GastoniaBETWEEN BrownSTREET & Craven

STREET

	SIZE	TYPE	LENGTH	INSTALLED	RETIRED	RENEWED
MAIN TO BLDG.	<u>3/4</u>	<u>Plastic</u>	<u>4'</u>	<u>12 21-91</u>		
MAIN TO PROP. LINE			<u>used to</u>	<u>tie-over to</u>		
PROP. LINE TO BLDG.				<u>Main</u>		

ENTERS:

BRANCHED INTO:

TAP SIZE: 3/8 PRESSURE 60 P.S.I. _____ INCHES W.C. LOCATION 250 West
of center Craven


PRESSURE TEST: @ 100 psi For 1/4 Hrs. By R/Dayes

MAIN-SIZE 4 C.I. _____ BARE STEEL _____ COATED STEEL _____ PLASTIC _____ YEAR INSTALLED 1991

DEPTH: 3 Ft. _____ In. LOCATION 16 South of center of Brown

"A" P/S READING P. TOTAL ANODES 1# _____ 17# _____ L.R. # _____

REMARKS:



Test Station		
Reading & Location	Lead	Volts
P/S Pipeline Lead - Red New Service	S	
P/S Pipeline Lead - White Existing Main	E	

ENG. DEPT. USE ONLY