

LOCATION 956 Brown St. CITY Gastonia  
BETWEEN Mcguire STREET & Craven STREET


	SIZE	TYPE	LENGTH	INSTALLED	RETIRED	RENEWED
MAIN TO BLDG.	<u>3/4</u>	<u>Plastic</u>	<u>3' used to</u>	<u>1-9-92</u>		
MAIN TO PROP. LINE			<u>tie-over to</u>			
PROP. LINE TO BLDG.			<u>MAIN</u>			

ENTERS: BRANCHED INTO:  
TAP SIZE: 3/4 PRESSURE 60 P.S.I. \_\_\_\_\_ INCHES W.C. LOCATION 42 East of center of Mcguire

PRESSURE TEST: @ 100 psi For 1 1/4 Hrs. By R. Hayes  
MAIN-SIZE 4 C.I. \_\_\_\_\_ BARE STEEL \_\_\_\_\_ COATED STEEL \_\_\_\_\_ PLASTIC ☒ YEAR INSTALLED 1991  
DEPTH: 3 Ft. \_\_\_\_\_ In. LOCATION 13 South of center of Brown

"A" P/S READING .4 TOTAL ANODES 1\* 1 17\* \_\_\_\_\_ L.R. # \_\_\_\_\_

REMARKS: Tracerwire not Bonded



Test Station		
Reading & Location	Lead	Volts
P/S Pipeline Lead - Red New Service	<u>R</u>	<u>1.5</u>
P/S Pipeline Lead - White Existing Main	<u>E</u>	

ENG. DEPT. USE ONLY