

LOCATION 1003 Brown St. CITY Gastonia
BETWEEN Bond St. STREET & Brown St. STREET

	SIZE	TYPE	LENGTH	INSTALLED	RETIRED	RENEWED
MAIN TO BLDG.	<u>3/4</u>	<u>P</u>	<u>4'</u>	<u>12-19-91</u>	<u>Tied over</u>	<u>34' of Existing</u>
MAIN TO PROP. LINE					<u>4" W Pipe to Existing</u>	
PROP. LINE TO BLDG.					<u>4" Plastic</u>	

ENTERS: 1003 BRANCHED INTO: 0

TAP SIZE: 1/2 PRESSURE 60 P.S.I. INCHES W.C. LOCATION 85 S of C of Brown St.


PRESSURE TEST: @ 100 psi For 1/4 Hrs. By RL

MAIN-SIZE 4" C.I. BARE STEEL COATED STEEL PLASTIC ☒ YEAR INSTALLED 1991

DEPTH: 2 Ft. 6 In. LOCATION 17' W of C of Arbury St.

"A" P/S READING 1.1 TOTAL ANODES 1# 17# L.R. #

REMARKS: Tied Tracer wire off at Tee



Test Station		
Reading & Location	Lead	Volts
P/S Pipeline Lead - Red New Service	<u>S</u>	<u>Riser 1.1</u>
P/S Pipeline Lead - White Existing Main	<u>E</u>	

ENG. DEPT. USE ONLY