

LOCATION 1033 Brown CITY BASTONIA

BETWEEN Jenkins STREET & ArKray STREET

	SIZE	TYPE	LENGTH	INSTALLED	RETIRED	RENEWED
MAIN TO BLDG.	<u>3/4</u>	<u>C+W Existing</u>	<u>4' Plastic</u>	<u>1-4-92</u>		
MAIN TO PROP. LINE			<u>to tie over</u>			
PROP. LINE TO BLDG.						

ENTERS: BRANCHED INTO:

TAP SIZE: 3/8 PRESSURE 60 P.S.I. INCHES W.C. LOCATION 386 West of

center of ArKray


PRESSURE TEST: @ 100 psi For 1/4 Hrs. By K Hayes

MAIN-SIZE 2 1/2 C.I.      BARE STEEL      COATED STEEL      PLASTIC   /   YEAR INSTALLED 1991

DEPTH: 3 Ft. In. LOCATION 17 South of center of Brown

"A" P/S READING 1.5 TOTAL ANODES 1#      17#      L.R. #     

REMARKS:



Test Station		
Reading & Location	Lead	Volts
P/S Pipeline Lead - Red New Service	<u>S R.</u>	<u>1.5</u>
P/S Pipeline Lead - White Existing Main	<u>E</u>	

ENG. DEPT. USE ONLY