

LOCATION

1911 Brownstone Ct.

CITY

Gastonia

BETWEEN

Moss Ct.

STREET &amp;

Yellowstone Ct.

STREET

	SIZE	TYPE	LENGTH	INSTALLED	RETIRED	RENEWED
MAIN TO BLDG.	3/4"	P	170'	2-28-96		
MAIN TO PROP. LINE	3/4"	P	45'			
PROP. LINE TO BLDG.	3/4"	P	127'			

ENTERS:

1911

BRANCHED INTO:

TAP SIZE:

1/2

PRESSURE

60

P.S.I.

INCHES W.C.

LOCATION

1800' W. of center of

Yellowstone Ct

PRESSURE TEST: @

100

psi

For

1/4 Hrs.

By

S. Hupfstedt

MAIN-SIZE

2"

C.I.

BARE STEEL

COATED STEEL

PLASTIC

YEAR INSTALLED

1988

DEPTH:

3 Ft.

0 In.

LOCATION

20' S. of center of Brownstone Ct

"A" P/S READING

P

TOTAL ANODES 1#


0

17#

L.R. #

92526

REMARKS:



Test Station

ENG. DEPT. USE ONLY

Reading &amp; Location

Lead

Volts

P/S Pipeline Lead - Red  
New Service

S

P/S Pipeline Lead - White  
Existing Main

E