

LOCATION 1930 Brownstone CITY Lanston
BETWEEN Yellowstone STREET & Mass Ct STREET


	SIZE	TYPE	LENGTH	INSTALLED	RETIRED	RENEWED
MAIN TO BLDG.	<u>3/4</u>	<u>Plastic</u>	<u>93</u>	<u>12-9-93</u>		
MAIN TO PROP. LINE	<u>3/4</u>	<u>"</u>	<u>4</u>			
PROP. LINE TO BLDG.	<u>3/4</u>	<u>"</u>	<u>89</u>			

ENTERS: 1930 BRANCHED INTO:
TAP SIZE: 1/2 PRESSURE _____ P.S.I. _____ INCHES W.C. LOCATION Side of house

PRESSURE TEST: @ 100 psi For 1/4 Hrs. By Barnett
MAIN-SIZE 2 C.I. _____ BARE STEEL _____ COATED STEEL _____ PLASTIC ☒ YEAR INSTALLED 1988
DEPTH: 2 Ft. 6 In. LOCATION 21' w of c apt

"A" P/S READING _____ TOTAL ANODES 1* _____ 17* _____ L.R. # 00453749

REMARKS:



Test Station		
Reading & Location	Lead	Volts
P/S Pipeline Lead - Red New Service	S	
P/S Pipeline Lead - White Existing Main	E	

ENG. DEPT. USE ONLY