

LOCATION 2051 BrownstoneCITY Houston

BETWEEN

Moss St

STREET &

STREET

	SIZE	TYPE	LENGTH	INSTALLED	RETIRED	RENEWED
MAIN TO BLDG.	<u>3/4</u>	<u>Plastic</u>	<u>45</u>	<u>5-26-94</u>		
MAIN TO PROP. LINE	<u>3/4</u>	<u>"</u>	<u>7</u>			
PROP. LINE TO BLDG.	<u>3/4</u>	<u>"</u>	<u>38</u>			

ENTERS: 2061BRANCHED INTO: 2051TAP SIZE: 3/4

PRESSURE

P.S.I.

INCHES W.C.

LOCATION

S side of housePRESSURE TEST: @ 100 psi For 1/4 Hrs. By BonettMAIN-SIZE 3/4" SerC.I. BARE STEEL COATED STEEL PLASTIC YEAR INSTALLED DEPTH: 1 Ft. 6 In.

LOCATION

W side of 2061"A" P/S READING TOTAL ANODES 1# 17#


L.R. #

0021284

REMARKS:

Test Station

ENG. DEPT. USE ONLY



Reading & Location

Lead

Volts

P/S Pipeline Lead - Red
New Service

S

P/S Pipeline Lead - White
Existing Main

E