

3549
LOCATION 3049 Bryant Cole Way CITY Gastonia
BETWEEN Gardarview STREET & Gardarview STREET


	SIZE	TYPE	LENGTH	INSTALLED	RETIRED	RENEWED
MAIN TO BLDG.	<u>3/4</u>	<u>P</u>	<u>171'</u>	<u>6-9-95</u>		
MAIN TO PROP. LINE	<u>1/1</u>	<u>11</u>	<u>43'</u>			
PROP. LINE TO BLDG.	<u>1/1</u>	<u>11</u>	<u>128'</u>			

ENTERS: 3049 BRANCHED INTO: —
TAP SIZE: 1/2 PRESSURE — P.S.I. — INCHES W.C. LOCATION 18' N. of C of
Bryant Cole way

PRESSURE TEST: @ 100 psi For 1/4 Hrs. By SP
MAIN-SIZE 2" C.I. — BARE STEEL — COATED STEEL — PLASTIC ✓ YEAR INSTALLED 1992
DEPTH: 3 Ft. 0 In. LOCATION —

"A" P/S READING P TOTAL ANODES 1* — 17* — L.R. # —

REMARKS:



Test Station		
Reading & Location	Lead	Volts
P/S Pipeline Lead - Red New Service	<u>OR</u>	<u>P</u>
P/S Pipeline Lead - White Existing Main	<u>E</u>	

ENG. DEPT. USE ONLY