

LOCATION	3570 BRYANA COLE WAY,	CITY	CASTORIA
----------	-----------------------	------	----------

BETWEEN Maria Lynn Ct. STREET & STREET

	SIZE	TYPE	LENGTH	INSTALLED	RETIRED	RENEWED
MAIN TO BLDG.	3/4'	P	65'	5-18-95		
MAIN TO PROP. LINE	3/4'	P	5'			
PROP. LINE TO BLDG.	3/4'	P	60			

ENTERS: 3570 BRANCHED INTO:

TAP SIZE: <u>1/2</u>	PRESSURE <u>60</u> P.S.I. <u> </u> INCHES W.C.	LOCATION <u>SB-S. of center of</u>
----------------------	-------------------------------------------------------	------------------------------------


PRESSURE TEST: @ 100 psi For 1/4 Hrs. By S. HUFFBETTER

MAIN-SIZE 2" C.I. BARE STEEL COATED STEEL PLASTIC ✓ YEAR INSTALLED 1992

DEPTH: 3 Ft. 0 In. LOCATION 18' w. of center of Bryant Cole way

"A" P/S READING <u>P</u>	TOTAL ANODES 1* <u>0</u> 17* <u>0</u>	L.R. # <u>233098</u>
--------------------------	---------------------------------------	----------------------

REMARKS:



Test Station		
Reading & Location	Lead	Volts
P/S Pipeline Lead – Red New Service	S	
P/S Pipeline Lead – White Existing Main	E	

ENG. DEPT. USE ONLY