

LOCATION 3625 Bryant Cole Way CITY Dallas
BETWEEN Jardonnain STREET & Marie Lynn STREET


	SIZE	TYPE	LENGTH	INSTALLED	RETIRED	RENEWED
MAIN TO BLDG.	<u>3/4</u>	<u>Plastic</u>	<u>106</u>	<u>6-23-94</u>		
MAIN TO PROP. LINE	<u>3/4</u>	<u>"</u>	<u>47</u>			
PROP. LINE TO BLDG.	<u>3/4</u>	<u>"</u>	<u>59</u>			

ENTERS: 3625 BRANCHED INTO:
TAP SIZE: 1/2 PRESSURE _____ P.S.I. _____ INCHES W.C. LOCATION Inside house

PRESSURE TEST: @ 100 psi For 14 Hrs. By Bonitt
MAIN-SIZE 2 C.I. _____ BARE STEEL _____ COATED STEEL _____ PLASTIC — YEAR INSTALLED 1992
DEPTH: 2 Ft. 6 In. LOCATION 22' W of apt

"A" P/S READING _____ TOTAL ANODES 1* _____ 17* _____ L.R. # 00219877

REMARKS:



Test Station		
Reading & Location	Lead	Volts
P/S Pipeline Lead - Red New Service	S	
P/S Pipeline Lead - White Existing Main	E	

ENG. DEPT. USE ONLY