

LOCATION 3641 Bryant Cole Way CITY GASTOWIA  
BETWEEN Jordan View Lane STREET & MARIA LYNN STREET


	SIZE	TYPE	LENGTH	INSTALLED	RETIRED	RENEWED
MAIN TO BLDG.	<u>3/4</u>	<u>P</u>	<u>33'</u>	<u>5-27-94</u>		
MAIN TO PROP. LINE	<u>3/4</u>	<u>P</u>	<u>17'</u>			
PROP. LINE TO BLDG.	<u>3/4</u>	<u>P</u>	<u>16'</u>			

ENTERS: 3641 BRANCHED INTO: 3649  
TAP SIZE: 3/4 straight tee PRESSURE 60 P.S.I. \_\_\_\_\_ INCHES W.C. LOCATION 225' E of 1st of Jordan View Lane

PRESSURE TEST: @ 100 psi For 1/4 Hrs. By RL  
Service MAIN SIZE 3/4 C.I. \_\_\_\_\_ BARE STEEL \_\_\_\_\_ COATED STEEL \_\_\_\_\_ PLASTIC ☒ YEAR INSTALLED 1994  
DEPTH: 2 Ft. 0 In. LOCATION 96' N of 1st of Bryant Cole Way

"A" P/S READING P TOTAL ANODES 1# \_\_\_\_\_ 17# \_\_\_\_\_ L.R. # 221 789

REMARKS:



Test Station		
Reading & Location	Lead	Volts
P/S Pipeline Lead - Red New Service	<u>S</u>	<u>P</u>
P/S Pipeline Lead - White Existing Main	<u>E</u>	

ENG. DEPT. USE ONLY