

LOCATION 3707 Bryant Cole WayCITY GastoniaBETWEEN Jordanview LnSTREET & Dead End

STREET

	SIZE	TYPE	LENGTH	INSTALLED	RETIRED	RENEWED
MAIN TO BLDG.	<u>3/4</u>	<u>P</u>	<u>112'</u>	<u>11-8-93</u>		
MAIN TO PROP. LINE	<u>3/4</u>	<u>P</u>				
PROP. LINE TO BLDG.	<u>3/4</u>	<u>P</u>				

ENTERS: 3707 Bryant Cole Way

BRANCHED INTO: -

TAP SIZE: 1/2PRESSURE 60


P.S.I.

INCHES W.C.

LOCATION

'N of Jordanview LnPRESSURE TEST: @ 100 psi For 1/4 Hrs. By S. GloneMAIN-SIZE 2" C.I. BARE STEEL COATED STEEL PLASTIC ✓ YEAR INSTALLED 1992DEPTH: 3 Ft. 0 In. LOCATION 'W of Bryant Cole Way"A" P/S READING P TOTAL ANODES 1* 17* L.R. # 425934

REMARKS:



Test Station		
Reading & Location	Lead	Volts
P/S Pipeline Lead - Red New Service	<u>S</u>	<u>P</u>
P/S Pipeline Lead - White Existing Main	<u>E</u>	

ENG. DEPT. USE ONLY