

LOCATION 3719 Bryant Cole Way CITY GASTONIA  
BETWEEN End of Cudesaack STREET & Jordanview Lane STREET


	SIZE	TYPE	LENGTH	INSTALLED	RETIRED	RENEWED
MAIN TO BLDG.	<u>3/4</u>	<u>Plastic</u>	<u>105'</u>	<u>6-03-96</u>		
MAIN TO PROP. LINE	<u>3/4</u>	<u>Plastic</u>	<u>50'</u>			
PROP. LINE TO BLDG.	<u>3/4</u>	<u>Plastic</u>	<u>55'</u>			

ENTERS: 3719 BRANCHED INTO: 0  
TAP SIZE: 1/2 PRESSURE 60 PSI \_\_\_\_\_ INCHES W.C. LOCATION 150' W of E of Jordanview Lane

PRESSURE TEST: @ 100 PSI FOR 1/4 HRS. BY RL  
MAIN-SIZE 2" C.I. \_\_\_\_\_ BARE STEEL \_\_\_\_\_ COATED STEEL \_\_\_\_\_ PLASTIC ✓ YEAR INSTALLED 1992  
DEPTH: 4 FT. 0 IN. LOCATION 22' S of E of Bryant Cole Way

"A" P/S READING Plastic N/A TOTAL ANODES 1# 0 17# 0 L.R. # 288940

REMARKS:



Test Station		
Reading & Location	Lead	Volts
P/S Pipeline Lead - Red New Service	<u>S</u>	<u>Riser Plastic</u>
P/S Pipeline Lead - White Existing Main	<u>E</u>	

ENG. DEPT. USE ONLY