

LOCATION 1430 BRYANT ST.

CITY Gastonia

BETWEEN IVA AVE

STREET &amp; Austin St

STREET

	SIZE	TYPE	LENGTH	INSTALLED	RETIRED	RENEWED
MAIN TO BLDG.	3/4	C/W	18'	8-4-94		
MAIN TO PROP. LINE	"	"				
PROP. LINE TO BLDG.	"	"				

ENTERS: 1434

BRANCHED INTO: 1430

TAP SIZE: 3/4

PRESSURE

P.S.I.

INCHES W.C.

LOCATION 79' E. of C of  
Bryant StPRESSURE TEST: @ 100 psi For 1/4 Hrs. By *JP*MAIN-SIZE 3/4 C.I. BARE STEEL COATED STEEL ☒ PLASTIC YEAR INSTALLED


DEPTH: 1 Ft. 6 In. LOCATION

"A" P/S READING 1.00

TOTAL ANODES 1# 17#

L.R. #

REMARKS: tested 3/4 pipe to tie back in serv.



Test Station

ENG. DEPT. USE ONLY

Reading & Location	Lead	Volts
P/S Pipeline Lead - Red New Service	<i>OR</i>	1.00
P/S Pipeline Lead - White Existing Main	E	