

LOCATION 1430 Bryant StCITY San FranciscoBETWEEN IVA AVE.STREET & AUSTIN AVE.

STREET

	SIZE	TYPE	LENGTH	INSTALLED	RETIRED	RENEWED
MAIN TO BLDG.	<u>3/4</u>	<u>Steel</u>	<u>19</u>			<u>Reactivated</u> <u>2-7-94</u>
MAIN TO PROP. LINE	<u>2 1/2</u>					
PROP. LINE TO BLDG.	<u>2 1/2</u>					

ENTERS: 1430

BRANCHED INTO:

TAP SIZE:	PRESSURE _____ P.S.I.	INCHES W.C.	LOCATION <u>End of House</u>
-----------	-----------------------	-------------	------------------------------


PRESSURE TEST: @ 100 psi For 14 Hrs. By Barnett

SERVICE MAIN-SIZE <u>3/4"</u>	C.I. _____	BARE STEEL _____	COATED STEEL <input checked="" type="checkbox"/>	PLASTIC _____	YEAR INSTALLED <u>?</u>
-------------------------------	------------	------------------	--	---------------	-------------------------

DEPTH: 1 Ft. 6 In. LOCATION 81' E of Apt

"A" P/S READING <u>060</u>	TOTAL ANODES 1* <u>1</u> 17* _____	L.R. # _____
----------------------------	------------------------------------	--------------

REMARKS:



Test Station		
Reading & Location	Lead	Volts
P/S Pipeline Lead - Red New Service	<u>S</u>	<u>90</u>
P/S Pipeline Lead - White Existing Main	<u>E</u>	

ENG. DEPT. USE ONLY