

LOCATION 11816 Buckeye Lv. CITY Cassville

BETWEEN Mapleleaf DR. STREET B STREET

	SIZE	TYPE	LENGTH	INSTALLED	RETIRED	RENEWED
MAIN TO BLDG	<u>3/4"</u>	<u>P</u>	<u>80'</u>	<u>2.15.99</u>		
MAIN TO PROP LINE	<u>3/4"</u>	<u>P</u>	<u>35'</u>			
PROP. LINE TO BLDG.	<u>3/4"</u>	<u>P</u>	<u>45'</u>			

ENTERS: 4816 BRANCHED INTO:

TAP SIZE: 3/4" PRESSURE 60 P S I INCHES W C LOCATION 88' N. of center of Buckeye Lv.


PRESSURE TEST: @ 100 psi For 1 1/4 Hrs. By SJA

MAIN - SIZE 2" C I BARE STEEL COATED STEEL PLASTIC ✓ YEAR INSTALLED 1997

DEPTH: 3 Ft. 3 in LOCATION 15' W. of center of Mapleleaf DR.

"A" P/S READING P TOTAL ANODES 1# 0 17# 0 L.R. # 104906

REMARKS:



Test Station		
Reading & Location	Lead	Volts
P/S Pipeline Lead - Red New Service	S	
P/S Pipeline Lead - White Existing Main	E	