

LOCATION 11050 Buckingham CITY Castonia
BETWEEN Laurel Lane STREET & STREET


	SIZE	TYPE	LENGTH	INSTALLED	RETIRED	RENEWED
MAIN TO BLDG.	<u>3/4</u>	<u>C/W</u>	<u>3'</u>	<u>Relocated 12-15-98</u>		
MAIN TO PROP. LINE						
PROP. LINE TO BLDG.						

ENTERS 11050 BRANCHED INTO 2
TAP SIZE: 3/4 ser. PRESSURE 60 PSI _____ INCHES W C LOCATION

PRESSURE TEST: @ 100 PSI FOR 114 HRS BY CP
MAIN-SIZE 3/4 C I _____ BARE STEEL _____ COATED STEEL ✓ PLASTIC _____ YEAR INSTALLED _____
DEPTH: 1 FT 6 IN LOCATION

"A" P/S READING 1.1 TOTAL ANODES 1# _____ 17# _____ L.R. # _____

REMARKS:



Test Station		
Reading & Location	Lead	Volts
P/S Pipeline Lead - Red New Service	S	<u>R. Ser 1.1</u>
P/S Pipeline Lead - White Existing Main	E	

ENG. DEPT. USE ONLY