

LOCATION

300 Buckskin Dr.

CITY

Gastonia

BETWEEN

Watugate Dr

STREET &

Ralph Blvd

STREET

	SIZE	TYPE	LENGTH	INSTALLED	RETIRED	RENEWED
MAIN TO BLDG	5/8"	P	50'	4-24-03		
MAIN TO PROP LINE	5/8"	P	15'			
PROP LINE TO BLDG	5/8"	P	35'			

ENTERS

300

BRANCHED INTO

TAP SIZE

3/4"

PRESSURE

60

PSI

INCHES W C

LOCATION

13' S. of center of
Watugate cor.

PRESSURE TEST @

100

PSI

FOR

1/4

HRS

BY

S.E.

MAIN SIZE

2"

C I

BARE STEEL

COATED STEEL

PLASTIC

YEAR INSTALLED

1997

DEPTH

3 FT

0 IN

LOCATION

14' N.W. of center of Buckskin Dr.

"A" P/S READING

P

TOTAL ANODES 1#

2


17#

2

LR #

105274

REMARKS



Test Station

Reading & Location	Lead	Volts
P/S Pipeline Lead - Red New Service	S	
P/S Pipeline Lead - White Existing Main	E	