

LOCATION 2005 Buck Thorne Ct CITY Gastonia  
BETWEEN Stonepine Pr. STREET & White cedar STREET

	SIZE	TYPE	LENGTH	INSTALLED	RETIRED	RENEWED
MAIN TO BLDG	3/4"	P	86'	11/14/00		
MAIN TO PROP LINE	3/4"	P	44'	11/14/00		
PROP LINE TO BLDG	3/4"	P	42'	11/14/00		

ENTERS 2005 Buck Thorne BRANCHED INTO Ø  
TAP SIZE 1/2" PRESSURE 60 PSI \_\_\_\_\_ INCHES W/C LOCATION 196' EAST of


PRESSURE TEST @ 100 PSI FOR 1/4 HRS BY D. Woody center of white cedar

MAIN-SIZE 2" C I \_\_\_\_\_ BARE STEEL \_\_\_\_\_ COATED STEEL \_\_\_\_\_ PLASTIC ☒ YEAR INSTALLED 1998

DEPTH 4' FT 0" IN LOCATION 13' south of center of Buck Thorne Ct.

"A" P/S READING N/A TOTAL ANODES 1# 0 17# 0 LR # 1078704

REMARKS new plastic service



Test Station		
Reading & location	Lead	Volts
P/S Pipeline Lead - Red New Service	S	plastic
P/S Pipeline Lead - White Existing Main	E	riser