

LOCATION 2009 Buckthorne Ct CITY Crastonia
BETWEEN White cedar Dr. STREET & stone pine Dr. STREET

| | SIZE | TYPE | LENGTH | INSTALLED | RETIRED | RENEWED |
|-------------------|------|------|--------|-----------|---------|---------|
| MAIN TO BLDG | 5/8" | P | 90' | 5-6-02 | | |
| MAIN TO PROP LINE | 5/8" | P | 32' | " | | |
| PROP LINE TO BLDG | 5/8" | P | 38' | " | | |

ENTERS 2009 BRANCHED INTO 6
TAP SIZE 3/4" PRESSURE 60 PSI INCHES W C LOCATION 216' East

PRESSURE TEST @ 100 PSI FOR 1/4 HRS BY g. cent. of White Cedar Dr.
D. Woody

MAIN-SIZE 2" C I BARE STEEL COATED STEEL PLASTIC ✓ YEAR INSTALLED 1999

DEPTH 3' FT 0" IN LOCATION 13' south of cent. of Buckthorne Ct.

"A" P/S READING N/A TOTAL ANODES 1# 0 17# 0 LR # 00088648

REMARKS New plastic service

| Test Station | | |
|--|------|---------|
| Reading & Location | Lead | Volts |
| P/S Pipeline Lead - Red New Service | S | plastic |
| P/S Pipeline Lead White Existing Main | E | rich |

