

LOCATION 218 Buckskin Dr. CITY Gastonia

BETWEEN Branching Iron Dr. STREET & Watergate Cir STREET

	SIZE	TYPE	LENGTH	INSTALLED	RETIRED	RENEWED
MAIN TO BLDG	3/4"	P	55'	6-26-00		
MAIN TO PROP LINE	3/4"	P	7'			
PROP LINE TO BLDG	3/4"	P	48'			

ENTERS 218 BRANCHED INTO

TAP SIZE 3/4" PRESSURE 60 PSI INCHES W C LOCATION 91' NE. of corner of Watergate Cir.


PRESSURE TEST @ 100 PSI FOR 1/4 HRS BY S.H.

MAIN-SIZE 2" C I  BARE STEEL  COATED STEEL  PLASTIC  YEAR INSTALLED 1997

DEPTH 3 FT 0 IN LOCATION 11' N. of center of Buckskin Dr.

"A" P/S READING P TOTAL ANODES 1# 0 17# 0 LR # 583797

REMARKS



Test Station		
Reading & Location	Lead	Volts
P/S Pipeline Lead - Red New Service	S	
P/S Pipeline Lead - White Existing Main	E	