

LOCATION 1817 Burt Ave. CITY Gastonia
BETWEEN Sinclair St. STREET & McNeil St. STREET

	SIZE	TYPE	LENGTH	INSTALLED	RETIRED	RENEWED
MAIN TO BLDG.						
MAIN TO PROP. LINE						
PROP. LINE TO BLDG.						

ENTERS: _____ BRANCHED INTO: _____
TAP SIZE: _____ PRESSURE _____ PSI _____ INCHES W.C. LOCATION _____


PRESSURE TEST: @ _____ PSI FOR _____ HRS BY _____
MAIN-SIZE 2" C.I. _____ BARE STEEL _____ COATED STEEL ☒ PLASTIC _____ YEAR INSTALLED 1958

DEPTH: 3' FT. 6" IN. LOCATION Burt Ave

"A" P/S READING 1.800 TOTAL ANODES 1# _____ 17# _____ L.R. # _____

REMARKS: Bonded insulator on existing 3/4" CW 1/8 service line. C.P. # 01872.

Reading: 1.034 before bond + 1.766 after bond was made.

	Test Station			ENG. DEPT. USE ONLY
	Reading & Location	Lead	Volts	
	P/S Pipeline Lead - Red New Service	S		
	P/S Pipeline Lead - White Existing Main	E		