

LOCATION 116 Burton Cir CITY GASTON, VA

BETWEEN Burton Cir. STREET & STREET

	SIZE	TYPE	LENGTH	INSTALLED	RETIRED	RENEWED
MAIN TO BLDG.	3/4"	P	124'	6-6-96		
MAIN TO PROP. LINE	3/4"	P	25'			
PROP. LINE TO BLDG.	3/4"	P	99'			

ENTERS: 116 BRANCHED INTO:

TAP SIZE: 1/2 PRESSURE 60 PSI  INCHES W.C. LOCATION 788' N. of center of

Burton Cir


PRESSURE TEST: @ 100 PSI FOR 1/4 HRS. BY S. WURSKAL

MAIN-SIZE 2" C.I.  BARE STEEL  COATED STEEL  PLASTIC ✓ YEAR INSTALLED 1991

DEPTH: 3 FT. 0 IN. LOCATION 13' E. of center of Burton Cir

"A" P/S READING P TOTAL ANODES 1# 0 17# 0 I.R. # 301892

REMARKS:

	Test Station			ENG. DEPT. USE ONLY
	Reading & Location	Lead	Volts	
	P/S Pipeline Lead - Red New Service	S		
	P/S Pipeline Lead - White Existing Main	E		